

Emission Test Certificate

Tuesday 29th April 2025

| | |
|----------------------------|---|
| Manufacturer | Topdeck International Pty Ltd (16 Salisbury Street, Silverwater, NSW 2128, Australia). |
| Product Name | Topdeck Flooring Engineered Timber. |
| Product Description | European Oak Veneer over Plywood Base -14 mm thickness |
| Date Tested | 15 th April 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231) |
| Test Method | ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”. |

Emission Data (24 hrs):

| | |
|--|--|
| Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2 | Topdeck Flooring Engineered Timber |
| Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr | Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.054 mg/m ² /hr |
| Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr | Formaldehyde Emission rate: 0.041 mg/m ² /hr |



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 29/04/2025

Expiry date: 29/04/2030

P25040065