

VOC Emission Test Certificate

Thursday 21st August 2025

Supplier: Topdeck International Pty Ltd (16 Salisbury Street, Silverwater, NSW 2128, AUSTRALIA).

Product Name: Topdeck Solid Timber - Premium Collection 18mm

Date Tested: 11th July 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2025 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Test Data (24 hrs):

Specification	
Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Topdeck Solid Timber - Premium Collection 18mm
Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate Limit: ≤0.500 mg/m ² /hr	Total Volatile Organic Compound (C ₆ -C ₁₆) Emission Rate: 0.007 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission Rate: 0.009 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant