

Emission Test Certificate

Tuesday 29th April 2025


Manufacturer	Topdeck International Pty Ltd (16 Salisbury Street, Silverwater, NSW 2128, Australia).
Product Name	Topdeck Flooring Engineered Timber.
Product Description	Timber Veneer over Plywood Base -14 mm thickness
Date Tested	15th April 2025 (Tested by FORAY Laboratories – NATA Accreditation 1231) ASTM
Test Method	D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia GreenStarDesign& AsBuilt V1.3 - 13.1.2B&13.2 Green Star Interiors V1.3 - 12.2	Topdeck Flooring Engineered Timber
Total Volatile Organic Compound (C6-C16) Emission Rate Limit: ≤ 0.500 mg/m ² /hr	Total Volatile Organic Compound (C6-C16) Emission Rate: 0.054 mg/m ² /hr
Formaldehyde Emission Rate Limit: ≤ 0.100 mg/m ² /hr	Formaldehyde Emission rate: 0.041 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant

Issued date: 29/04/2025

Expiry date: 29/04/2030

P25040065