## **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: Topdeck International Pty Ltd

16 Salisbury Street Silverwater NSW 2128 **Test Number** : 17-000094

24/01/2017

**Print Date** : 24/01/2017

**Issue Date** 

Sample Description Clients Ref : "Wooden Land Engineered European Oak"

Engineered timber floorboards

Colour : Natural End Use : Flooring

Nominal Composition: European Oak Veneer over plywood base

Nominal Mass per Unit Area/Density: 750kg/m3

Nominal Thickness: 15mm

AS/ISO 9239.1-2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

**Radiant Heat Source** 

Date of Sample Arrival 16/01/2017
Date Tested 24/01/2017

 CHF Value
 1
 2
 3
 Mean

 Length
 3.7
 4.2
 3.4
 3.8
 kW/m²

 Width
 6.4
 kW/m²

Smoke Value 1 2 3 Mean

 Length
 6
 6
 9
 7 %.min

 Width
 50
 % min

Blistering Yes
Glowing Yes
Smouldering Yes

81022 16954 Page 1 of 2

 Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025
- Chemical Testing
- Mechanical Testing

985

: Accreditation No. : Accreditation No.

983



Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA

Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results

relate only to the sample or samples tested. This document shall not be reproduced except in full and shall

S140 M

MICHAEL A. JACKSON B.Sc.(Hons)

## **AWTA Product Testing**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

## **TEST REPORT**

Client: Topdeck International Pty Ltd

> 16 Salisbury Street Silverwater NSW 2128

Test Number : 17-000094 **Issue Date** 24/01/2017

**Print Date** 24/01/2017

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

81022 16954 Page 2 of 2

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing - Mechanical Testing

: Accreditation No.

983



Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test

Samples and their identifying descriptions have been provided by the client unless otherwise stated.

relate only to the sample or samples tested. This document shall not be reproduced except in full and

SADY

A. JACKSON B.Sc.(Hons)