

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N. 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O. Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

CLIENT : TOPDECK INTERNATIONAL PTY LTD
T/A TOPDECK FLOORING
1/14 CHURCHILL STREET
SILVERWATER NSW 2128

TEST NUMBER : 7-598783-AN
ISSUE DATE : 05/08/2014
PRINT DATE : 18/08/2014

SAMPLE DESCRIPTION Clients Ref: "Prime Registered Embossed 12.3mm
9901-10 Series"
Laminated flooring
Colour tested: Lime, various colours available
Approximate Thickness: 12.3mm

Material Specification:

Clear paper cellulose wear layer impregnated with aluminium oxide and
melamine/photographic decorative layer, HDF core impregnated with melamine,
re-cycled paper base impregnated with melamine, paraffin waxed locking
joints Nominal total density: 850g/cm3 +/-20g/cm3

ASISO 9239.1-2003

Reaction to Fire Tests for Floorings
Determination of the Burning Behaviour
using a Radiant Heat Source

Date of sample arrival: 08/07/2014

Date tested: 04/08/2014

Results:

	1	2	CHF Value	3	Mean	
Length	5.4	4.9		4.9	5.1	kW/m2
Width	8.9	-		-	-	kW/m2

	1	2	Smoke Value	3	Mean	
Length	7	5		5	6	% min
Width	8	-		-	-	% min

Observations: Glowing

Note: Sample was conditioned in accordance with BSEN 13238-2001 at a
temperature of 23+/-2degC and Relative Humidity of 50+/-5% for a minimum of
48 hours prior to testing

Each specimen was clamped to a substrate of 6mm fibre reinforced cement
board prior to testing

The test results relate to the behaviour of the test specimens of a product
under the particular conditions of the test, they are not intended to be the
sole criterion for assessing the potential fire hazard of the product in use

208184

1

(END OF REPORT)

PAGE 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



This Laboratory is accredited by the National Association of Testing Authorities, Australia, for:
-Chemical Testing of Textiles & Related Products : Accreditation No. 983
-Mechanical Testing of Textiles & Related Products : Accreditation No. 985
-Heat & Temperature Measurement : Accreditation No. 1356

This document is issued in accordance with NATA's accreditation requirements. Samples, and their
identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no
warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the
sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if
amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in
advertising providing the content and format of the advertisement have been approved in advance by the
Managing Director of AWTA Ltd.



APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR