AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Topdeck International Pty Ltd

> 16 Salisbury Street Silverwater NSW 2128

15-004897 Test Number :

Print Date

Issue Date 29/10/2015 29/10/2015

"Prime Luxury Edition Laminate" **Sample Description** Clients Ref:

> Engineered flooring product End Use : Floating Floors

Nominal Composition: Aluminium oxide wear layer/melamine decorative layer/ high density fibre

core

860kg/m3 Nominal Mass per Unit Area/Density:

Nominal Thickness: 12.3mm

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a **Radiant Heat Source**

Date of Sample Arrival 28/09/2015 **Date Tested** 28/10/2015

CHF Value 1 2 3 Mean Non Directional 86 97 8 0 88 kW/m² Smoke Value 1 2 3 Mean Non Directional 4 % min

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2001 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was clamped to a substrate of 6mm thick fibre reinforced cement board prior to testing.

No directional properties, three specimens tested only.

39924 7737 Page 1 of 1

Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Chemical Testing Mechanical Testing

Performance & Approvals Testing

: Accreditation No Accreditation No · Accreditation No.

983 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by

APPROVED SIGNATORY

. JACKSON B.Sc.(Hons)